

2025 Consumer Confidence Report (CCR)
Annual Water Quality Report

Franklin Pierce University
Rindge, NH
PWS #1994010

We are pleased to present to you our Annual Drinking Water Quality Report, also known as the Consumer Confidence Report. This report, a requirement of the 1996 amendments to the Safe Drinking Water Act, is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Water Source

Franklin Pierce University obtains its water from four bedrock wells. Your water is then treated to remove iron and manganese, and sodium hypochlorite is added for disinfection. Treated water is stored in a 500,000-gallon atmospheric storage tank which is connected to the distribution system pipes.

White Water, Inc. provides Franklin Pierce University with contract operation services. The contract operation includes the services of a state certified operator who monitors the water system for compliance with all state and federal drinking water regulations. The operating contract also includes services such as making emergency repairs when needed, making recommendations for improving water quality and increasing system reliability.

We currently do not have any regularly scheduled meetings, however, if you have any questions about this report or concerning your water system, please contact WhiteWater, Inc. at (888) 377-7678. We want our valued customers to be informed about their water system.

Source Water Assessment

A water assessment of Franklin Pierce University was completed by the New Hampshire Department of Environmental Services (NHDES). The updated assessment report can be found on the NHDES website at: <https://www.des.nh.gov/climate-and-sustainability/conservation-mitigation-and-restoration/source-water-protection/assessment> The assessment found that this public drinking water source has a medium susceptibility to potential sources of contamination in 2 criteria in each well, and low susceptibility in 10 other criteria.

Additional source water assessment information can be found at the Environmental Protection Agency's website: <https://www.epa.gov/sourcewaterprotection/source-water-assessments>

Source Water Protection

Source water is untreated water from streams, rivers, lakes, or underground aquifers that is used to supply public drinking water. Preventing drinking water contamination at the source makes good public health, economic, and environmental sense. You can be aware of the challenges of keeping drinking water safe and take an active role in protecting drinking water. There are lots of ways that you can get involved in drinking water protection activities to prevent the contamination of the ground water source: dispose properly of household chemicals, help clean up the watershed that is the source of your community's water, attend public meetings to ensure that the community's need for safe drinking water is considered in making decisions about land use, etc. Contact our office for more information on source water protection or contact the Environmental Protection Agency (EPA) at 1.800.426.4791. You may also find information on EPA's website at <https://www.epa.gov/sourcewaterprotection>

Water Quality

Franklin Pierce University routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table shows any detection resulting from our monitoring for the period of January 1 to December 31, 2025. It is important to remember that the presence of these contaminants does not necessarily pose a health risk.

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. All sources of drinking water are subject to potential contamination by substances that are naturally occurring, or manmade. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants** can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the number of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The table below lists all the drinking water contaminants that were detected throughout water quality monitoring and testing. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk.

Test Results

Unless otherwise noted, testing was done in 2025.

Unless otherwise noted, the highest concentration of each contaminant that was collected has been reported.

Contaminant	Violation (Y/N)	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
Total Coliform Bacteria	N	ND	highest number of positive samples (monthly)	Absent	1 positive	Naturally present in the environment.
Inorganic Contaminants						
Barium (2023)	N	0.0016	mg/L	2	2	Erosion of natural deposits.
Fluoride (2023)	N	0.37	mg/L	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nickel (2023)	N	0.15	mg/L	-	0.1	Geological; electroplating, battery production, ceramics
Nitrate (2/11/2025)	N	ND	mg/L	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium (2023)	N	31	mg/L	20	100-250	Erosion of natural deposits, urban storm runoff.
Sulfate (2023)	N	17	mg/L	250	-	Erosion of natural deposits; urban storm runoff.
Chloride (2023)	N	67	mg/L	250	250	Erosion of natural deposits; storm water runoff containing road salt.
Contaminants including Pesticides & Herbicides						
Synthetic Organic Compounds (SOCs) (2/11/2025)	N	ND	ug/L			Herbicides, pesticides, and other chemicals that come from agriculture, urban storm water runoff, or industrial, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
Volatile Organic Chemicals (VOCs) (2/11/2025)	N	ND	ug/L			

Methyl Tertiary-butyl ether (MtBE) (Quarterly 2025)	N	ND	ug/L	13	13	A gasoline additive
Disinfection Byproducts						
Chlorine (Monthly 2024)	N	0.06-4.03	ppm	4	4	Water additive used for disinfection.
Total Haloacetic Acids (HAA5) (9/11/2025)	N	ND-1.1	ug/L	0	60	A byproduct of drinking water chlorination.
Total Trihalomethanes (TTHMs) (9/11/2025)	N	7.3	ug/L	0	80	A byproduct of drinking water chlorination.
Secondary Contaminants						
Iron (2023)	N	3.6	ppm	-	0.3	Naturally occurring, corrosion of cast iron pipes
Manganese (2023)	N	28	ug/L	50	300	Erosion of natural deposits

Per- and Polyfluoroalkyl Substances (PFAS) Tested in 2024						
PFAS are a large, complex group of synthetic chemicals used in various consumer products. We are required to track the following four.						
Contaminant	Violati on (Y/N)	Level Detected	Unit Measure ment	MCLG	MCL	Likely Source of Contamination
PFHxS – Perfluorohexane Sulfonic Acid	N	ND	ppt	-	18	Discharges and emissions from industrial and manufacturing sources associated with the production or use of these PFAS, including production of moisture and oil-resistant coatings on fabrics and other materials. Additional sources include the use and disposal of products containing these PFAS, such as fire-fighting foams. corrosion of household plumbing systems.
PFNA – Perfluorononanoic Acid	N	ND	ppt	-	11	
PFOS – Perfluorooctane Sulfonic Acid	N	ND	ppt	-	15	
PFOA – Perfluorooctanoic Acid	N	0.800	ppt	-	12	
Health Effects for PFAS: Some people who drink water containing these PFAS in excess of the MCL may experience certain adverse effects. These could include effects on the liver, blood, immune system, thyroid, and fetal development. These PFAS may also elevate the risk of certain cancers.						

Lead & Copper – last tested in 2025						
Contaminant	Violation (Y/N)	Level Detected	Unit Measurement	MCLG	AL	Likely Source of Contamination
Lead – 90 th Percentile	N	3	ppb	0	15	Corrosion of household plumbing systems.
Copper – 90 th Percentile	N	0.4	mg/L	1.3	1.3	Corrosion of household plumbing systems.
Number of lead samples collected: 10 Number of sites exceeding lead action level: 0 Number of copper samples collected: 10 Number of sites exceeding copper action level: 0						

**Note: the state allows us to monitor for some contaminants less than once a year because the concentrations of these contaminants do not change frequently. Not all contaminants are tested for every year due to monitoring waivers and therefore we use the most recent round of sampling. Some of the data presented is more than one year old, however, is limited to no older than five years.*

Units of Measurement:

Parts per million (ppm) or Milligrams per liter (mg/L)	A measurement that corresponds to one minute in two years, or a single penny in \$10,000.
Parts per billion (ppb) or Micrograms per liter (µg/L)	A measurement that corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Picocuries per liter (pCi/L) or Micrograms per liter (µg/L)	Measurements of radioactivity in water.
Millirems per year (mrem/year)	A measurement of radiation absorbed by the water.
Nephelometric Turbidity Unit (NTU)	A measurement of the clarity of water; turbidity more than 5 NTU is just noticeable to the average person.
Million fibers per liter (MFL)	A measurement of the presence of asbestos fibers that are longer than 10 micrometers.

Definitions:

Action Level (AL)	the concentration of contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Treatment Technique (TT)	a required process intended to reduce the level of a contaminant in drinking water.
Maximum Contaminant Level (MCL)	the highest level of a contaminant that is allowed in drinking water; MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal (MCLG)	the level of a contaminant in drinking water below which there is no known or expected risk to health; MCLGs allow for a margin of safety.

Drinking Water Equivalent Level (DWEL)	a lifetime exposure concentration protective of adverse, non-cancer health effects, that assumes all the exposure to a contaminant is from a drinking water source.
Maximum Residual Disinfectant Level (MRDL)	the highest level of a disinfectant allowed in drinking water; there is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	the level of drinking water disinfectant below which there is no known or expected risk to health; MRDLGs do reflect the benefits of the use of disinfectants to control microbial contaminants.
Running Annual Average (RAA)	the average of all monthly or quarterly samples for the last year at all sample locations.
Non-Detect (ND)	the specified contaminant was not detected.
Level 1 Assessment	a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria has been found in the water system.
Level 2 Assessment	a very detailed study of the water system to identify potential problems and determine (if possible) why an E. Coli MCL violation has occurred and/or why total coliform bacteria has been found in the water system on multiple occasions.

IMPORTANT INFORMATION

- Lead & Copper:** Samples are generally collected, and action levels measured at the consumer's tap. 90% of the tests for a given system must be equal to or below the action level; therefore, a section of the results above has been calculated and are listed as the 90th percentile.
- Lead:** **Major sources in drinking water:** corrosion of household plumbing systems; erosion of natural deposits.
Health effects statement: Infants and children who drink water containing lead more than the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink water containing lead more than the action level over many years could develop kidney problems or high blood pressure.
- Copper:** **Major sources in drinking water:** corrosion of household plumbing systems; erosion of natural deposits.
Health effects statement: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper more than the action level over many years could, suffer liver or kidney damage. People with Wilson's Disease should consult their doctor.

Arsenic:	The United States Environmental Protection Agency (US EPA) adopted the new MCL standard of 10ppb in October 2001. Water systems were required to meet this new standard by January 1 2006.
Total Coliform:	Reported as the highest monthly number of positive samples for water systems that take less than 40 samples per month. Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful bacteria, may be present.
Turbidity:	Turbidity has no health effects, however, can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms, that can include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

As you can see by the table, our system had no violations. We are proud that your drinking water meets all Federal and State requirements. The EPA has determined that your water IS SAFE at these levels.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1 (800) 426-4791.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center of Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1 (800) 426-4791.

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Franklin Pierce University is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact WhiteWater at 888-377-7678. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

Health Effects of Lead Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse

health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Lead In Schools Per RSA 485:17-a, all NH schools and licensed child care facilities must test for lead at all drinking water outlets where children can drink the water and to remediate any outlets testing at or above 5 ppb. Three rounds of testing at least 6 months apart are required. A comprehensive list of facilities and results are available at www.gettheleadoutnh.org

LEAD SERVICE LINE INVENTORY (SLI)

In 2024 a Lead Service Line Inventory of your system was created. The purpose is to identify any remaining service lines which include material that is Lead, Galvanized Requiring Replacement (GRR), or unknown materials which may increase your risk of exposure to lead in drinking water. All service lines identified as lead or galvanized requiring replacement are required to be replaced on a schedule approved by NHDES. For more information on all service lines in our water system, contact WhiteWater at 888-377-7678.

We, at Franklin Pierce University, work hard to provide top quality water to every tap. Water is a limited resource, so it is vital that we all work together to maintain it and use it wisely. We ask that all our customers help us protect and preserve our drinking water resources, which are the heart of our community, our way of life, and our children's future. Please contact us with any questions. Thank you for working together for safe drinking water.